



PhilGEPS

Philippine Government Electronic Procurement System

Central Portal for
Philippine Government
Procurement Opportunities

Bid Notice Abstract

Request for Quotation (RFQ)

Reference Number 9020397

Procuring Entity NATIONAL MUSEUM - MANILA METRO MANILA

Title REPAIR OF FIRE SPRINKLER SYSTEM AT NATIONAL MUSEUM OF NATURAL HISTORY BUILDING

Area of Delivery Metro Manila

Solicitation Number:	REQUEST FOR QUOTATION NO. BAC 2022-46	Status	Active
Trade Agreement:	Implementing Rules and Regulations	Associated Components	2
Procurement Mode:	Negotiated Procurement - Small Value Procurement (Sec. 53.9)	Bid Supplements	0
Classification:	Goods - General Support Services	Document Request List	1
Category:	General Repair and Maintenance Services	Date Published	16/09/2022
Approved Budget for the Contract:	PHP 590,000.00	Last Updated / Time	16/09/2022 00:00 AM
Delivery Period:	60 Day/s	Closing Date / Time	22/09/2022 10:00 AM
Client Agency:			
Contact Person:	Edwin J. Dela Rosa Head, BAC Secretariat P. Burgos St. Ermita Manila Metro Manila Philippines 1000 63-02-2981100 Ext.1014 bac@nationalmuseum.gov.ph		

Description

The National Museum of the Philippines (NMP), through the Bids and Awards Committee (BAC) Secretariat, Support Procurement Unit (SPU), invites all eligible suppliers/ merchants/ contractors to bid for the project mentioned above. Bids received in excess of the ABC shall be automatically rejected. The procurement will be conducted through Alternative Mode of Procurement - Negotiated Procurement, Section 53.9 (Small Value Procurement) of the 2016 Revised IRR of R.A. 9184 otherwise known as the "Government Procurement Reform Act".

Approved Budget for the Contract (ABC): Five Hundred Ninety Thousand Pesos (PHP 590,000.00)
Please see attached Technical Specifications.
Bids must be duly received by the BAC Secretariat SPU through manual submission at the office address indicated below. LATE BIDS SHALL NOT BE ACCEPTED.

In view thereof, the BAC Secretariat SPU requests the submission of your Price Quotation/Bid Proposal for the above project on or before September 22, 2022, not later than 10:00 A.M. Kindly place your quotation/bid proposal in a SEALED ENVELOPE together with three (3) copies of the following documentary requirements:

- PhilGEPS Registration Number;
- Mayor's /Business Permit;
- Income/Business Tax Return, and;
- Notarized Omnibus Sworn Statement (GPBB-Prescribed Form).

The envelope shall bear the following:

- Title of the project to be bid,
- PhilGEPS Posting Reference Number,
- Name, Address, and Contact Number of the bidder, and
- Addressed to the information indicated below.

The NMP reserves the right to reject any and all bids, declare a failure of bidding, or not award the contract at any time prior to contract award in accordance with Sections 35.6 and 41 of the 2016 revised IRR of RA No. 9184,

without thereby incurring any liability to the affected bidder or bidders

For further information, please refer to:
Mr. Edwin J. dela Rosa,

Head - BAC Secretariat

2/F, BAC Room, North Annex of the
National Museum of Fine Arts Building (Motorpool),

Padre Burgos Street, Manila 1000

Tel. No. 8298-1100 Local 1014

(SGD)

EDWIN J. DELA ROSA

Head - BAC Secretariat

Bids and Awards Committee

Created by Edwin J. Dela Rosa

Date Created 15/09/2022

The PhilGEPs team is not responsible for any typographical errors or misinformation presented in the system. PhilGEPs only displays information provided for by its clients, and any queries regarding the postings should be directed to the contact person/s of the concerned party.

© 2004-2022 DBM Procurement Service. All rights reserved.

[Help](#) | [Contact Us](#) | [Sitemap](#)



PAMBANGSANG MUSEO NG PILIPINAS
NATIONAL MUSEUM OF THE PHILIPPINES
PROJECT PROFILE

TITLE: Repair of Fire Sprinkler System at National Museum of Natural History Building

LOCATION: National Museum of Natural History (NMNH), Ermita, Manila

IMPLEMENTING UNIT: Facilities Management Division (FMD)

DESCRIPTION: The National Museum of Natural History (NMNH) building is equipped with fire sprinkler system, using one set of jockey and fire pump, that should maintain pressurized water inside the system. The pressurized water then suppresses fire during an incident through the aid of sprinkler heads and fire hoses scattered in the entire building.

Upon our assessment, there are parts of the system that need to be repaired in order to rectify the defective areas and incorrect pipeline layout.

OBJECTIVE: To maintain the effective performance and operations of fire sprinkler system of NMNH Building and to provide a satisfactory and safe physical environment for the public and the National Museum collection.

- SCOPE OF WORK** (for Infrastructure Projects)
- TECHNICAL SPECIFICATIONS** (for Goods/Services Projects)
- TERMS OF REFERENCE** (for Consulting Services Projects)

ITEM	MINIMUM SPECIFICATIONS
BLACK IRON (B.I.) PIPES AND FITTINGS (90° ELBOW)	Sizes: 100mm, 40mm, 15mm dia. Schedule: 40
CHECK VALVE	Sizes: 100mm, 40mm
BALL VALVE	Sizes: 100mm, 40mm

- COVERAGE OF WORKS**
1. Mobilization/Demobilization
 2. Project Management and Supervision
 3. Tools and Equipment
 4. Relocation of Pressure Relief Valve (PRV) connection, Fire Hose Cabinet (FHC), sensing line, and connection of jockey pump suction line
 5. Programming and pressure setting of Fire and jockey pump controller (existing)
 6. Painting Works (Primer and Top Coat)
 7. Consumables
 8. Testing and Commissioning Works
 9. Hydrotesting of Fire Sprinkler System

RESPONSIBILITIES:

1. The Contractor shall ensure that personnel to be assigned at the NMP Buildings are well screened, technically and professionally trained, courteous, cooperative, efficient, reliable, trustworthy, well-groomed, physically and mentally fit. No personnel shall be assigned who has not been approved by the FMD.
2. The Contractor and its personnel shall agree to abide by the safety and security requirements of the NMP. They must comply with the NMP's House Rules and Regulations, directives, instructions and other existing rules and regulations while inside the premises.
3. The Contractor's personnel shall subject themselves to security checks, but not limited to examination of the person and/or his/her personal belongings.
4. The Contractor shall ensure that its personnel wear their proper company working uniform equipped with appropriate Personal Protective Equipment (PPE) and identification cards during the course of the contract inside the NMP's premises. Loitering inside the NMP's premises is not allowed.
5. The Contractor shall provide/equip all its personnel with the tools during the course of the contract without any additional cost to the NMP.
6. The Contractor shall see to it that the area is clean and in its original condition after the course of the contract. Any damage/s caused by the Contractor's personnel shall be

restored by the Contractor at no additional cost to the NMP.
 7. All other items of work not specifically mentioned but are necessary to complete the works shall be provided by the Contractor at no additional cost to the NMP.

SUBMITTALS: None

SOURCE OF FUND: Budget is available and shall be chargeable against General Fund under MOOE - Repairs and Maintenance – Other Machinery and Equipment for Fiscal Year 2022.

APPROVED BUDGET FOR CONTRACT: Five Hundred Ninety Thousand Pesos (Php 590,000.00), inclusive of all applicable taxes.

COMPLETION TIME: The contract shall be effective for **Sixty (60) Calendar Days** reckoned from the date stated in the Notice to Proceed (NTP) to be issued by FMD.

TERMS OF PAYMENT:
 The contract price shall be **fully paid upon project completion and acceptance.**

WARRANTY: The Supplier shall provide **One (1) year warranty** against factory defects and workmanship reckoned from the date of completion and acceptance. Form of warranty shall be as specified in Section 62.1 of the IRR of R.A. 9184, the Government Procurement Reform Act and its Implementing Rules and Regulations.





CONTRACTOR'S ELIGIBILITY: Requirements for Small-Value Procurement

LIQUIDATED DAMAGES:
 When the contractor fails to satisfactorily deliver goods/services under the contract within the specified delivery schedule, inclusive of duly granted time extensions, if any, the contractor shall be liable for damages for the delay and shall pay the procuring entity liquidated damages, not by way of penalty, an amount equal to 1/10 of 1% of the cost of the delayed contract scheduled for every day of delay until such goods/services are finally delivered and accepted by the procuring entity concerned. In no case shall the sum of the liquidated damages exceed 10% of the total contract price, in which the procuring entity concerned may rescind the contract and impose appropriate sanctions over and above the liquidated damages.

PRE-TERMINATION CLAUSE:
 The contract is effective on the date indicated in the NTP and shall remain in full force for **Sixty (60) calendar days** or until terminated by either party (National Museum or Contractor) upon prior written notice by either party. Termination process shall follow the prescribed procedure under IRR-A.R.A. 9184.

The National Museum reserves the right to pre-terminate the contract after Fifteen (15) calendar days via written notice to the Contractor, if in National Museum's opinion, after due verification of facts, the Contractor is not providing satisfactory services or is not complying with the Terms and Conditions of the Contract. The grounds for the termination of the Contractor by the National Museum include but not limited to the following:

1. Violation(s) of any of the terms and conditions of the Contract; and
2. Any other act or omission by the Contractor or its service technicians which is detrimental or prejudicial to the interest of the National Museum, its employee(s), or the public.

Prepared by:  RAYMOND ALEXIS R. DOLOROTA Administrative Officer V - FMD Date:	Checked & Reviewed by:  ARNEL NELSON L. AQUINO Architect IV / OIC, FMD Date:
Recommending Approval:  ATTY. MA. ROSEANNE M. FLORES-AVILA Deputy Director-General for Administration Date:	Approved by:  JEREMY BARNS, CES0 III Director-General Date: